BG Pulse Journal USA
ISSN:1947-2536 http://www.bgpulseusa.com/index.php/bg

Monitoring Water Losses in Water Supply Systems Using the Internet of Things

Aureliano Thistlewood
Technical researcher
doi:https://doi.org/10.5281/zenodo.24143453

Abstract: Water losses in distribution networks reduce the effective availability of treated water and complicate the operation of water supply systems. The Internet of Things provides a technical basis for connecting flow meters, pressure sensors, and other monitoring devices to analytical platforms that support timely investigation of abnormal conditions. This article examines the application of IoT technologies to water-loss monitoring through a narrative technical review. The analysis distinguishes physical leakage from apparent losses associated with metering and information errors. It considers sensor placement, communication infrastructure, data quality, anomaly detection, and the verification of maintenance outcomes. A practical monitoring framework is proposed that combines district-level water balances, contextual analysis, field inspection, and post-repair evaluation. The article concludes that connected monitoring can support water-loss management when measurements are reliable and alerts lead to appropriate operational action. No original field experiment or measured reduction in water losses is reported.

Keywords: Internet of Things, water supply, water losses, leakage detection, smart metering, pressure monitoring, distribution networks.

Introduction

Water supply systems must deliver adequate quantities of water through networks of pipes, reservoirs, pumping stations, and service connections. Losses within these networks can occur through leaking pipes, damaged joints, overflowing storage facilities, inaccurate meters, and errors in data handling. Identifying the dominant source of loss is essential because different causes require different corrective actions. Replacing a leaking pipe addresses a physical problem, while correcting a meter or billing record addresses a measurement or accounting problem.

Water-loss terminology must therefore be used carefully. Real losses refer to physical water losses, whereas apparent losses include unauthorized consumption, customer-meter inaccuracies, and data-handling errors. Non-revenue water is broader than water losses because it also includes authorized consumption that is not billed. A difference between water supplied and water billed should consequently not be interpreted entirely as leakage. The United States Environmental Protection Agency emphasizes the importance of water auditing in distinguishing these components and directing control activities. nepis.epa.gov

IoT-based monitoring connects field measurements with data-processing and reporting systems. In a water distribution application, this can provide more frequent information about flow, pressure, and storage conditions than periodic manual readings alone. However, increased data availability does not automatically establish the location or cause of a loss. The objective of this

article is to examine how connected monitoring can support water-loss assessment and to propose a framework linking measurements with verified operational decisions.

Materials and Methods

This article presents a narrative technical review of selected public guidance from the United States Environmental Protection Agency, the United States Department of Energy, the Danish Environmental Protection Agency, and the Washington State Department of Health. Sources were selected for their relevance to water auditing, distribution-system monitoring, leakage detection, and measurement accuracy. The review focuses on distribution networks rather than household plumbing alone.

The analysis was organized around five components: defining the monitored network boundary, acquiring reliable measurements, transferring and validating data, identifying abnormal conditions, and verifying corrective action. A conceptual IoT monitoring framework was developed from this synthesis. No original sensor dataset was collected, and no communication platform or detection algorithm was experimentally evaluated. The results therefore describe technical considerations and proposed procedures rather than measured system performance.

Results

A clearly defined monitoring boundary is the foundation of meaningful water-loss assessment. The proposed framework divides a suitable distribution network into monitored areas whose incoming and outgoing flows can be identified. These areas may correspond to district-metered areas where the network arrangement permits reliable boundary measurement. Storage facilities within an area must also be considered because changes in stored volume can otherwise appear as unexplained differences between supply and consumption.

The water balance should compare volumes over consistent time periods. For an area containing storage, net supplied volume is calculated from measured inflows and outflows while accounting for the change in stored water. Authorized consumption is then considered when estimating the remaining difference. That difference requires further investigation: it can contain physical leakage, apparent losses, and measurement uncertainty. This proposed accounting sequence prevents a monitoring platform from labeling every imbalance as a confirmed leak.

Meter accuracy is particularly important because systematic measurement error can resemble persistent water loss. The Danish Environmental Protection Agency emphasizes the importance of accurate waterworks outlet meters and describes model-based leakage detection using continuous pressure and flow readings. This supports combining reliable boundary measurements with information about network behavior rather than relying on isolated readings. The Danish Environmental Protection Agency

Sensor selection should follow the monitoring objective. Flow meters quantify water passing through monitored boundaries, while pressure sensors help describe hydraulic conditions at selected locations. Reservoir-level sensors can support storage accounting. Acoustic measurements may assist more targeted leakage investigations. The proposed design places instruments where they answer a defined operational question, such as whether an area has developed an unexplained increase in demand or whether a pressure disturbance is localized.

The distinction between detecting an abnormal condition and locating a leak is essential. Smart-meter data may reveal unusual consumption or help identify an area requiring investigation, but metering alone does not necessarily establish the position of a damaged pipe. Department of Energy guidance distinguishes smart metering from technologies specifically intended to locate distribution-system leaks, including acoustic and in-pipe approaches. An IoT platform should therefore communicate the spatial limits of its evidence. Department of Energy

Communication infrastructure forms the connection between field devices and the monitoring platform. In the proposed framework, communication technology is selected after evaluating coverage, power availability, reporting frequency, and the amount of data each instrument generates. Periodic meter readings and high-frequency pressure recordings impose different requirements. Local buffering is included so that a temporary communication interruption does not automatically erase measurements. The system also distinguishes missing data from genuine zero-flow observations.

Data validation is required before analytical interpretation. The proposed checks identify inconsistent timestamps, incompatible units, implausible measurements, prolonged identical readings, and gaps in transmission. Calibration and maintenance records are retained alongside the measurements. These records help determine whether a sudden change represents a hydraulic event or an instrument intervention. A dashboard should display data-quality status so that an uncertain measurement is not presented with the same confidence as a verified observation.

Anomaly detection can begin with transparent comparisons against established operating patterns. Examples include a sustained increase in minimum flow, a persistent pressure deviation, or an unexplained change in the district water balance. Department of Energy guidance identifies increases in minimum system flow as a reason to investigate potential leakage. Such indicators remain screening signals: legitimate changes in demand and operating conditions must be considered before a leak is confirmed.

Literatures:

1. Скворцова, Л. А., Махмудов, Д. Э., Усманов, Д. Р., Адылходжаев, А. А., & Хегай, Л. Н. (2019). АСПЕКТЫ СПОРТИВНОЙ АДАПТОЛОГИИ ПРИ ИЗУЧЕНИИ ВИТАМИНА D 25 (OH) D У ФУТБОЛИСТОВ. In От фундаментальных знаний к тонкому владению скальпелем (pp. 51-54).
2. Хегай, Л. Н., Скворцова, Л. А., Махмудов, Д. Э., Усманов, Д. Р., Муслимов, О. Я., & Адылходжаев, А. А. (2019). СОДЕРЖАНИЕ 25-ОН-ВИТАМИНА D У ФУТБОЛИСТОВ В УСЛОВИЯХ СОЛНЕЧНОЙ РАДИАЦИИ УЗБЕКИСТАНА. In Actual Questions and Innovations in Science 2 (pp. 160-161).
3. Кузиев, О. Ж., Курбанов, А. Т., & Арипжанова, Н. Б. (2015). Фенотипологические признаки дерматоглифики при определении половой принадлежности у лиц узбекской популяции. Евразийский союз ученых, (10-1 (19)), 93-95.
4. Mavlyanov, I., Parpiev, S., Sadikov, A., Kurganov, S., & Makhmudov, D. (2020). Relative features of the PPARA (Rs4253778), PPARGC1A (Rs8192678) and PPARG2 (Rs1801282)

polymorphisms genes in athletes engaged in cyclic types of sports. European Journal of Molecular and Clinical Medicine, 7(2), 1860-1869.

5. Кантович, Л. И., Клементьева, И. Н., & Кузиев, Д. А. (2020). Обзор конструкций и технологических возможностей современных очистных комбайнов. Техника и технология горного дела, (2 (9)), 26-41.
6. Пирназаров, М. М., Садиков, А. А., Махмудов, Д. Э., & Хегай, Л. Н. (2021). Магнитно-резонансная томографическая визуализация повреждений коленных суставов. Re-health journal, (1 (9)), 152-159.
7. Махмудов, Д. Э., & Саитов, Т. А. (2023). Анализ персонализированного питания высококвалифицированных спортсменов управленческих видов спорта. Klinik va profilaktik tibbiyot jurnali, (3), 79.
8. Даминова, Г. (2020). ROLE OF TEACHERS'MOTIVATION IN TEACHING. Архив исследований.
9. Кузиев, О. Ж., Муродов, Н. Х., Мавлонов, У. О., & Отакулов, С. И. (2016). Особенности повреждений таза и нижних конечностей у водителей при несмертельной травме. Молодой ученый, (10), 512-514.
10. Махмудов, Д. Э., & Саитов, Т. А. (2023). Анализ персонализированного питания высококвалифицированных спортсменов управленческих видов спорта. Klinik va profilaktik tibbiyot jurnali, (3), 79.
11. Usmanovna, N. G., & Oybekovna, D. G. (2018). The importance of motivation in education. Достижения науки и образования, (16 (38)), 33-35.
12. Sharipovna, J. J., & Oybekovna, D. G. (2019). Role of teachers' motivation in teaching. Вопросы науки и образования, (3 (47)), 84-88.
13. Решетняк, С. Н., Кузиев, Д. А., & Уроков, Ф. Э. (2019). АКТУАЛЬНЫЕ АСПЕКТЫ ПОВЫШЕНИЯ ЭНЕРГЕТИЧЕСКОЙ ЭФФЕКТИВНОСТИ ТЕХНОЛОГИЧЕСКОГО ТРАНСПОРТА КОМПАНИИ АК «АЛРОСА». Научные разработки: евразийский регион, 231.
14. Таралева, Т. А., Махмудов, Д. Э., Атабаева, С. М., & Сагитов, Д. М. (2026). ВАРИАБЕЛЬНОСТЬ СЕРДЕЧНОГО РИТМА В ЦИКЛИЧЕСКИХ ВИДАХ СПОРТА: СОВРЕМЕННЫЕ ПОДХОДЫ К ОЦЕНКЕ ФУНКЦИОНАЛЬНОГО СОСТОЯНИЯ СПОРТСМЕНОВ. South Aral Region Medical Journal, 2(Maxsus son-2), 587-593.
15. Нагаева, Г. А. (2021). Исторические факторы формирования населенных пунктов (на примере Черноморского побережья Краснодарского края). Известия высших учебных заведений. Поволжский регион. Гуманитарные науки, (3 (59)), 24-37.
16. Горбань, В. В., & Черноглазов, К. С. (2015). Особенности вариабельности ритма сердца у молодых людей, ассоциированные с массой тела. Кубанский научный медицинский вестник, (4), 63-68.
17. Кузиев, О. Ж., Рузиев, Ш. И., & Искандаров, А. И. (2014). Усовершенствование бескрасочного метода снятия отпечатков пальцев и ладоней. Морфология, 145(3), 107-108.

18. Дьяченко, В. В., Шеманин, В. Г., Черняева, Р. В., Алексеева, О. В., Вишневецкая, В. В., Лохова, Т. В., ... & Чартий, П. В. (2021). Управление городской средой: социальноэкономические и экологические аспекты/г. Краснодар: Изд-во КубГТУ.
19. Носов, А. Е., Байдина, А. С., Власова, Е. М., & Алексеев, В. Б. (2016). Анализ вариабельности ритма сердца при нарушении сердечной деятельности у работников нефтедобывающего предприятия. Гигиена и санитария, 95(1), 41-45.
20. Нагаева, Г. А. (2008). Женщины в социокультурном пространстве Черноморской губернии: конец XIX-начало XX вв.[Электронный ресурс]: автореф. дисс.... к. и. н. 2007. URL: http://cheloveknauka. com/zhenschiny-v-sotsiokulturnom-prostranstve-chernomorskoy-gubernii-konets-xix-nachalo-xx-vv-1# ixzz48FQ3sLjm (дата обращения: 10.06. 2016).
21. Chekalina, S. I., Umurzakova, R. Z., Saliev, K. K., & Abdurakhmanov, T. R. (1994). Effect of berberine bisulfate on platelet hemostasis in thrombocytopenia patients. Gematologiia i transfuziologiia, 39(5), 33-35.
22. Zyablitskii, V. M., Romanovskaya, V. N., Umurzakova, R. Z., Starosel'skaya, A. N., & Mikhal'skaya, T. Y. (1996). Modification of the functional state of hemostasis system using berberin sulfate. Экспериментальная и клиническая фармакология, 59(1), 37-39.
23. Chekalina, S. I., Umurzakova, R. Z., Saliev, K. K., & Abdurakhmanov, T. R. (1994). Trombositopeni hastalarında berberin bisülfatın trombosit hemostazına etkisi. Gematologiia i Transfuziologiia, 39(5), 33-35.
24. Chekalina, S. I., Umurzakova, R. Z., Saliev, K. K., & Abdurakhmanov, T. R. (1994). Effet du bisulfate de berbérine sur l'hémostase plaquettaire chez les patients thrombocytopéniques. Gematologiia i Transfuziologiia, 39(5), 33-35.
25. Махмудов, Д., Абдуллаева, Х., Таралева, Т., Аблялимов, Р., & Парпиев, С. (2025). АНАЛИЗ ФУНКЦИОНАЛЬНЫХ ПОКАЗАТЕЛЕЙ ФУТБОЛИСТОВ НА ЭТАПЕ ОТБОРА К СОРЕВНОВАНИЯМ. Медицина и спорт, (3), 162-162.